Cooling		1	-	least the heating season 'Average'.				
	Cooling		Υ	Average (mandatory)		Y	Y	
Heating		Υ		Warmer (if designed)		Υ		
				Colder (if designed)		N		
Item	symbol	value	unit	Item	symbol	value	unit	
	gn load			Seasonal eff				
Cooling	Pdesignc	7.1	kW	Cooling	SEER	7.0	-	
Heating/Average	Pdesignh	5.6	kW	Heating/Average	SCOP/A	4.2		
Heating/Warmer	Pdesignh	5.7	kW	Heating/Warmer	SCOP/W	5.4		
Heating/Colder Pdesignh / kW			Heating/Colder	SCOP/C	/ /			
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj				
Tj = 35 °C	Pdc	7.11	kW	Tj = 35 °C	EERd	3.58	-	
Гј = 30 °C	Pdc	5.18	kW	Tj = 30 °C	EERd	5.29	-	
Tj = 25 °C	Pdc	3.33	kW	Tj = 25 °C	EERd	8.46	-	
Гј = 20 °С	Pdc	2.86	kW	Tj = 20 °C	EERd	12.52	-	
Declared capacity (*) for heating/Average season, at indoor temperature				Declared coefficient of performance (*)/Average season, at indoor temperature				
20 °C and outdoor temperature Tj Tj = - 7 °C	Dalla	4.02	1-14/	20 °C and outdoor temperature Tj	COD4	2.05		
<u>- </u>	Pdh	4.82	kW	Tj = - 7 °C	COPd	2.85		
Tj = 2 °C	Pdh	2.92	kW	Tj = 2 °C	COPd	4.07		
Tj = 7 °C	Pdh	1.98	kW	Tj = 7 °C	COPd	5.53		
Γj = 12 °C	Pdh	2.45	kW	Tj = 12 °C	COPd	6.81		
Tj = bivelant temperature	Pdh	5.66	kW	Tj = bivelant temperature Tj = operating limit	COPd	2.01		
Tj = operating limit	Pdh	5.66	kW		COPd	2.01	-	
Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				
Tj = 2 °C	Pdh	5.71	kW	Tj = 2 °C	COPd	2.69	-	
Tj = 7 °C	Pdh	3.60	kW	Tj = 7 °C	COPd	5.25	-	
Tj = 12 °C	Pdh	2.45	kW	Tj = 12 °C	COPd	6.81	-	
Γj = bivelant temperature	Pdh	5.71	kW	Tj = bivelant temperature	COPd	2.69	-	
Tj = operating limit	Pdh	5.71	kW	Tj = operating limit	COPd	2.69	-	
Declared capacity (*) for heating/C	older season, a	t indoor ten	perature	Declared coefficient of performance (*)/Co	lder season, at	indoor tempe	rature 2	
20 °C and outdoor temperature Tj				°C and outdoor temperature Tj				
Гj = - 7 °С	Pdh	3.73	kW	Tj = - 7 °C	COPd	2.93		
Γj = 2 °C	Pdh	2.25	kW	Tj = 2 °C	COPd	4.13		
Γj = 7 °C	Pdh	1.98	kW	Tj = 7 °C	COPd	5.53		
Гj = 12 °С	Pdh	2.45	kW	Tj = 12 °C	COPd	6.81	_	
Γj = bivalent temperature	Pdh	4.82	kW	Tj = bivalent temperature	COPd	1.82	-	
Tj = operating limit	Pdh	5.20	kW	Tj = operating limit	COPd	1.86	-	
Tj = - 15 °C Pdh		-	kW	Tj = - 15 °C	COPd	-	-	
Bivalent temperature				Operating limit temperature				
Heating/Average	Tbiv	-10	°C	Heating/Average	Tol	-10	°C	
Heating/Warmer	Tbiv	2	°C	Heating/Warmer	Tol	2	°C	
Heating/Colder				Heating/Colder	Tol	-20	°C	
Cycling interval capacity			Cycling interval efficiency					
For Cooling	Pcycc	x,x	kW	For Cooling	EERcyc	x,x		
For Heating	Pcych	x,x	kW	For Heating	COPcyc	x,x	-	
Degradation co-efficient cooling (**) Cdc 0.25 -			Degradation co-efficient cooling (**)	Cdh	0.25			
Electric power input in power modes other than 'active mode'			Annual electricity consumption					
Off Mode	P off	0.00509	kW	Cooling	Q _{Ce}	355	kWh/a	
Standby Mode	P _{SB}	0.00509	kW	Heating/Average	QHE	1867	kWh/a	
Thermostat-Off Mode	Рто	0.00211/ 0.01388	kW	Heating/Warmer	Q _{HE}	1478	kWh/a	
Crankcase Heater Mode P _{CK} 0		kW	Heating/Colder	Q _{HE}	/	kWh/a		
Capacity control (indicate one of the	ree options)			Other items				
Fixed Staged	N N			Sound power level (indoor/outdoor) Global warming potential	L _{WA}	(64/70) 675	dB(A)	
					GWP	(1250/360	q.	
Variable Contact details for obtaining more		Y		NO-CHO MIZUHO-KU, NAGOYA, 467-0855 JAP	-	0)	m³/h	

(*)For staged capacity units, two values divided by a slash ('/') will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit.

(**)If default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.