MODEL: UTN-1	7AP /UTG-17	AP		If function includes heating: Indicate the h to. Indicated values should relate to one he least the heating season 'Average'.			
Cooling		Υ		Average (mandatory)		Y	
Heating		Υ		Warmer (if designed)		Y	
				Colder (if designed)		N	N
Item	symbol	value	unit	Item	symbol	value	unit
Desig	n load			Seasonal ef	ficiency		
Cooling	Pdesignc	4.6	kW	Cooling	SEER	6.4	-
Heating/Average	Pdesignh	3.7	kW	Heating/Average	SCOP/A	4.0	-
Heating/Warmer	Pdesignh	3.6	kW	Heating/Warmer	SCOP/W	5.1	-
Heating/Colder	Pdesignh	x.x	kW	Heating/Colder	SCOP/C	x.x	-
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio (*), at indoor temperature 27(19) °C and outdoor temperature Tj			
Tj = 35 °C	Pdc	4.61	kW	Tj = 35 °C	EERd	3.24	-
Tj = 30 °C	Pdc	3.30	kW	Tj = 30 °C	EERd	4.83	-
Tj = 25 °C	Pdc	2.14	kW	Tj = 25 °C	EERd	7.52	-
Tj = 20 °C	Pdc	1.25	kW	Tj = 20 °C	EERd	11.22	-
Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Average season, at indoor temperature 20 $^{\circ}\text{C}$ and outdoor temperature Tj			
Tj = - 7 °C	Pdh	3.34	kW	Tj = - 7 °C	COPd	2.97	-
Tj = 2 °C	Pdh	1.99	kW	Tj = 2 °C	COPd	4.08	-
Tj = 7 °C	Pdh	1.32	kW	Tj = 7 °C	COPd	4.67	-
Tj = 12 °C	Pdh	0.95	kW	Tj = 12 °C	COPd	5.16	-
Tj = bivelant temperature	Pdh	3.70	kW	Tj = bivelant temperature	COPd	2.32	-
Tj = operating limit	Pdh	3.34	kW	Tj = operating limit	COPd	2.97	-
Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	3.73	kW	Tj = 2 °C	COPd	2.61	
rj = 7 °C	Pdh	2.31	kW	Tj = 7 °C	COPd	5.08	
Tj = 12 °C	Pdh	1.08	kW	Tj = 12 °C	COPd	5.87	
Tj = bivelant temperature	Pdh	3.73	kW	Tj = bivelant temperature	COPd	2.61	
Tj = operating limit	Pdh	3.73	kW	Tj = operating limit	COPd	2.61	
Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Colder season, at indoor temperature 2 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	N/A	kW	Tj = - 7 °C	COPd	N/A	-
Tj = 2 °C	Pdh	N/A	kW	Tj = 2 °C	COPd	N/A	-
Tj = 7 °C	Pdh	N/A	kW	Tj = 7 °C	COPd	N/A	-
Tj = 12 °C	Pdh	N/A	kW	Tj = 12 °C	COPd	N/A	-
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	-
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COPd	N/A	-
Tj = - 15 °C	Pdh	N/A	kW	Tj = - 15 °C	COPd	N/A	-
Bivalent temperature			Operating limit temperature				
Heating/Average	Tbiv	-7	°C	Heating/Average	Tol	-10	°C
Heating/Warmer	Tbiv	2	°C	Heating/Warmer	Tol	2	°C
Heating/Colder	Tbiv	х	°C	Heating/Colder	Tol	x	°C
Cycling interval capacity				Cycling interval efficiency			
For Cooling	Pcycc	x,x	kW	For Cooling	EERcyc	X,X	
For Heating	Pcych	x,x	kW	For Heating	COPcyc	x,x	
Degradation co-efficient cooling (**)		0.25	-	Degradation co-efficient cooling (**)	Cdh	0.25	
Electric power input in power modes				Annual electricity consumption	Culi	0.25	
Off Mode		0.002036	kW	Cooling	0-	251	kWh/a
Standby Mode	P OFF	0.002036	kW	Heating/Average	Qce	1295	kWh/a
Thermostat-Off Mode	P _{TO}	0.00552/	kW	Heating/Warmer	Q _{не}	988	kWh/a
	_	0.02513					
Crankcase Heater Mode P _{CK} 0 kW Capacity control (indicate one of three options)				Heating/Colder	QHE	-	kWh/a
	e options)			Other items		(F0 (CT)	Jests
Fixed		N N		Sound power level (indoor/outdoor) Global warming potential	GWP	(58/63) 675	dB(A
Variable		Y		Rated air flow (indoor/outdoor)	-	(850/1950)	q. m³/l
Contact details for obtaining more						,/	, ,,
access of access of access of the contract of the contra	TOVOTOMI (O., LTD, 5-17	MOMOZON	NO-CHO MIZUHO-KU, NAGOYA, 467-0855 JAF	ΔN		

^(*)For staged capacity units, two values divided by a slash ('/') will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit.

(**)If default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.